



*Office of the City Engineer ◊ Telephone (209) 385-6846 ◊ Facsimile (209) 385-6211
678 West 18th Street, Merced, Ca. 95340*

September 16, 2020

**RE: Gerard Ave Sewer Main Hwy 99 to Kibby Rd
Project # 117020**

Subject: Response to Request for Information (RFI)

Question 1 – Is the Contractor responsible for the CCTV Inspection on the Sewer Line or does the City still do it themselves?

Answer – CCTV Inspection will be considered part of testing performed by the contractor and will be included with 10-1.24 Sanitite HP Sewer Main and all associated line items.

A handwritten signature in blue ink, appearing to read "Michael Beltran II".

Michael Beltran II, P.E.
City Engineer