



**MERCED**

# CITY OF MERCED

---

*Office of the City Engineer ♦ Telephone (209) 385-6846 ♦ Facsimile (209) 385-6211*  
678 West 18th Street, Merced, Ca. 95340

---

## REQUEST FOR INFORMATION NO. 1

September 14, 2023

**RE: Bel Air Sewer Line  
Project # CP 220033**

**Subject: Response to Request for Information (RFI No. 1)**

**Question 1** – How are we to do testing and disinfection on the water main crossings over the sewer line and fire hydrant installations?

**Answer** –City forces will be doing the wet water connections with material supplied by the Contractor and will do disinfection on the water line, no pressure testing will be required on the mainline but disinfection and pressure testing will be required on the fire hydrant installations.

**Question 2** – With City forces doing the televising of the new sewer line, is an air test required?

**Answer** –Yes, air testing on the sewer will be required by the Contractor and mandrel testing.

John Ainsworth, P.E.  
Interim Senior Engineer