



# CITY OF MERCED

## MERCED

### RESPONSE TO REQUEST FOR INFORMATION (RFI No. 1)

Project: CP240031 WWTP Transformer Replacement

Date: October 24, 2024

**Question 1** – Would you please decrease the Liquidated damages? The bond company won't issue the bond.

**Answer:** We are considering an addendum to lower the liquidated damages.

**Question 2** – Who purchases primary new wires?

**Answer:** The bidding contractor must purchase primary new wire.

**Question 3** – PCB test is required for oil?

**Answer:** A PCB test is required.

Richard Maddox, P.E.  
Interim City Engineer