



CITY OF MERCED

MERCED

RESPONSE TO REQUEST FOR INFORMATION (RFI No. 1)

Project: Craig Drive Sewer Main – CP250064

Date: February 6, 2025

Question 1 - Does the city have a layover yard for material and equipment storage for the length of the project?

Answer: Yes, a layover yard for material and equipment can be made available upon request during the Pre-Con meeting after project award.

Question 2 - Can equipment be parked and left on sight overnight?

Answer: No, equipment will be moved at the end of each work day.

Question 3 - For asphalt pave back over trenching am I supposed to include that cost in my install quote?

Answer: Yes, proposal should include this as part of the install cost for each bid item involving trenching. As example from the specifications:

Payment for Item 10-1.13, "8" C900 Water Main," shall be at the contract unit price, in one item: "8" C900 Water Main" as set forth in the proposal and shall include all labor, materials, tools, equipment, excavation, backfill, compaction, sterilization, **asphalt paving**, aggregate base and all work necessary for the completion of this item.

Question 4 - It says the bid bond is only 10%. Is that 100% confirmed before I submit to my bonding company?

Answer: Yes, Bid Bond is 10% of the total bid price.

Question 5 - Is this project DBE? The subcontractors list states Non-DBE and DBE.

Answer: There is no DBE percentage requirement on the project, but it should still be indicated if the subcontractors are DBE on the list of subcontractors.

Richard Maddox, P.E.
Senior Engineer