

SINGLE OR DOUBLE LEAF GATES				
NOM HEIGHT (H)	UPRIGHT HT (U)	FRAME HT (F)		
WITHOUT BARBED WIRE	ACTUAL DIM	ACTUAL DIM		
3'-0"	2'-10"	2'-8 1/2"		
3'-6"	3'-4"	3'-2 1/2"		
4'-0"	3'-10"	3'-8 1/2"		
5'-0"	4'-10"	4'-8 1/2"		
6'-0"	5'-10"	5'-8 1/2"		
7'-0"	6'-10"	6'-8 1/2"		
8'-0"	7'-10"	7'-8 1/2"		
9'-0"	8'-10"	8'-8 1/2"		
10'-0"	9'-10"	9'-8 1/2"		
11'-0"	10'-10"	10'-8 1/2"		
12'-0"	11'-10"	11'-8 1/2"		

SINGLE LEAF GATES			
OPENING	GATE POSTS	HINGE SPACE (S)	
FACE TO FACE	SQ & RND SIZES	POST TO UPRIGHT	
3'-0" THROUGH 6'-0"	2 1/2" SQ OR 2.875" OD	FOR SQUARE & ROUND GATE POSTS: 2 1/4"	
7'-0" THROUGH 10'-0"	3" SQ OR 4" OD	FOR SQUARE & ROUND GATE POSTS: 2 1/4"	
11'-0" THROUGH 12'-0"	4" SQ OR 4" OD	FOR SQUARE & ROUND GATE POSTS: 2 1/4"	
13'-0" THROUGH 18'-0"	6" SQ OR 6.625" OD	FOR GATE POSTS: SQ-2 1/4" RND-3 1/2"	
19'-0" THROUGH 20'-0"	8" SQ OR 8.625" OD	FOR GATE POSTS: SQ-2 1/4" RND-3 1/2"	

	DOUBLE LEAF GATES		
OPENING	GATE POSTS	HINGE SPACE (S)	
FACE TO FACE	SQ & RND SIZES	POST TO UPRIGHT	
8'-0" THROUGH 12'-0"	2 1/2" SQ OR 2.875" OD	FOR SQUARE & ROUND GATE POSTS: 2 1/4"	
14'-0" THROUGH 24'-0"	THROUGH OR		
26'-0" THROUGH 36'-0"	6" SQ OR 6.625" OD	FOR GATE POSTS: SQ-2 1/4" RND-3 1/2"	
38'-0" THROUGH 40'-0"	8" SQ OR 8.625" OD	FOR GATE POSTS: SQ-2 1/4" RND-3 1/2"	

NOTE:

CENTER UPRIGHT REQUIRED ON GATE LEAVES $8'\!-\!0"$ & WIDER. CENTER RAIL REQUIRED ON GATE LEAVES $10'\!-\!0"$ & HIGHER.

	ENGINEERING	DEPARTMENT		
-				

CITY OF MERCED, CA.

IYI	PICAL	SWING	GAILS	WITHOUT	RAKRFD	MIKE

DRAWN: SER
ENG.
REVISED 8/10

PROVED BY: 1 Jucker CITY ENGINEER 4/4/06

F-10

SHEET OF