






PLAN
NTS



SECTION A-A
NTS



SECTION B-B
NTS

NOTES

1. SAMPLING MH TO BE LOCATED OUTSIDE OF PUBLIC RIGHT-OF-WAY EXCEPT WITH WRITTEN APPROVAL OF THE CITY ENGINEER.
2. AN ALTERNATE DESIGN BY A REGISTERED ENGINEER MAY BE SUBMITTED FOR REVIEW.
3. LOCATION SUBJECT TO THE APPROVAL OF THE CITY ENGINEER.
4. ALL SURFACE WATER MUST DRAIN AWAY FROM SAMPLING MANHOLE.
5. A WATERSTOP CONSISTING OF A STD. MANHOLE ADAPTER GASKET AS SUPPLIED BY THE PIPE MFR. TO BE GROUTED INTO THE BOX WALL NEAR THE CENTER OF THE WALL.

ENGINEERING DEPARTMENT

CITY OF MERCED, CA.

SAMPLING MANHOLE

S-5B

DRAWN: KGE

APPROVED BY:

DATE

ENG.

REVISED: 1/02

CITY ENGINEER

SHEET

OF