

## NOTES:

- COMPACTION BY PONDING OR JETTING SHALL NOT BE ALLOWED.
  MINIMUM REQUIREMENTS ARE SHOWN. SEE PROJECT SPECIFICATIONS FOR FURTHER REQUIREMENTS.
  TRENCHES 5 FEET OR MORE IN DEPTH SHALL BE SHORED AS REQUIRED BY ARTICLE 6 DIVISION OF
- 5.
- INDUSTRIAL SAFETY CONSTRUCTION SAFETY ORDERS (SEC. 6424 CALIF. LABOR CODE).

  SEE CITY STANDARD T-2 FOR PORTLAND CEMENT CONCRETE PAVEMENT.

  MAXIMUM LIFT THICKNESS FOR INITIAL AND STRUCTURAL BACKFILL SHALL BE .67 FEET BEFORE COMPACTION.

  AGGREGATE BASE SHALL BE A MINIMUM OF 13-INCHES THICK FOR ALL ARTERIAL STREETS, EXPRESSWAYS, AND TRANSITWAYS.

ENGINEERING DEPARTMENT			CITY OF MERCED, CA.	
TRENCH EXCAVATION AND BACKFILL			<del></del>	1
DRAWN: MP DATE:	APPROVED BY:	3/17/08	-	<b>-  </b>
REVISED: 3/17/08	CITY ENGINEER	7/1//-5	SHEET	OF